

Certification Record

Customer	Class	File Number
Vulcan Electric Company 28 Endfield St, Porter ME USA 04068	<u>4813-02</u> TEMPERATURE-INDICATING AND REGULATING EQUIPMENT-Other Than Appliance Type	023541_0_000

Note: These devices are not certified for safety, appliance or water heater use unless so stated below.

MISCELLANEOUS CONTROLS

Probe type thermostats, Model 1A1B2, 1A1B9, 1A2B2, 1A2B9, 1B1B2, 1B1B9, 1B2B2, 1B2B9, 1C1B2, 1C1B9, 1C2B2, 1C2B9, 1D1B2, 1D1B9, 1D2B2, 1D2B9, 1E1B2, 1E1B9, 1E2B2, 1E2B9, 1G1B2, 1G1B9, 1G2B2 and 1G2B9, 120/240V ac, 10/5A, 120V dc, 2A, 100,000 operations. The controls are Certified for component use only. Date code, see Illustration 1.